

Outstanding value, service and expertise.

Managing Risk: Preventing Legionella

What's at Risk?

Legionella is a type of bacterium found naturally in fresh water. When people are exposed to the bacterium, it can cause illness (Legionnaires' disease and Pontiac fever).

This bacterium grows best in warm water, like the kind found in:

 Hot tubs Cooling towers

- Large plumbing systems
- Hot water tanks
- · Decorative fountains

Let's get your clients covered.

People are exposed to Legionella when they breathe in a mist or vapor (small droplets of water in the air) containing the bacteria. Each year, 8,000–18,000 people in the United States are hospitalized with Legionnaires' disease. According to the U.S. Centers for Disease Control and Prevention, between 5% and 10% of those afflicted with the disease die.

What are Your Legal Obligations?

Property owners and managers have a common law duty to exert a high level of care for its employees and visitors to its facilities. Legionella has the potential to surface at any building. Many facilities harbor the bacteria in small quantities without issue, but maintaining proper standards and preventative maintenance of cooling towers and plumbing systems is imperative to keep legionella at bay and help lower risk of an outbreak.

Ongoing testing and upkeep is essential as there is no water treatment and maintenance system guaranteed to fully and permanently eradicate the organism. If your property resides in New York the NYSDOH put in place emergency regulations, which are directed towards owners of cooling towers, hospitals and residential health care facilities.



A New York hotel was sued by the family of a woman who died from sepsis due to Legionella pneumonia after using the pool and hot tub while attending a wedding the month prior. The lawsuit claims the hotel "was negligent, grossly negligent and reckless in maintaining its pool and hot tub."

The family is seeking damages in the millions for negligence, wrongful death, and pain and suffering.

Checklist: Controlling Exposures to Legionella

How can You Better Protect Your Organization?

- Disinfect cooling towers regularly. At a minimum twice yearly washout and cleaning programs should be in place, including oxidizing disinfections.
- Disinfect ice storage chests in ice machines regularly.
- Store domestic hot water at 140°F and deliver it at a minimum of 122°F. High temperatures effectively kill the bacteria. Unfortunately, even a few degrees below 122°F, legionella thrives and multiplies quickly, so it's imperative that temperatures stay in a safe range.
- If cold water tanks are located in direct sunlight insulate them in order to keep temperatures below 68; avoid locating them in sunlight if possible.

- Maintain anti-corrosion and scale prevention programs. Legionella thrives in scale and mineral deposits in water lines – especially warm water lines – so be sure that those lines remain clean. Use scale inhibitors where appropriate.
- Install and maintain high-efficiency mist eliminators on cooling towers. According to early reports, it
 appears that those who contracted the disease were not in the impacted buildings at all, rather they were
 exposed to the mist that rained down to the street from the cooling towers.
- Adopt a comprehensive water treatment program and maintain stringent recording policies to ensure preventative measures are taken in a timely manner. This can include activities like cleanings, biocide addition, etc.
- Control pH levels; pH between 5.0 and 8.5 are most at risk and regularly check the cooling tower for evidence of biofouling (accumulation of microorganisms, plants, algae, or animals on wetted surfaces). Legionella often use common amoebae or protozoa as host organisms, so by controlling the overall microbiological population, you can inhibit legionella growth.
- Create an interdisciplinary response team. Responding to Legionella and other infectious waterborne
 pathogens found in your water system requires a team effort. This team should include someone in your
 organization with knowledge of safety and health issues, your water treatment company representative, a
 laboratory with Legionella expertise, and a Legionella risk management professional. The team can
 provide a proactive plan for prevention as well as develop an emergency action plan to follow if needed.

Claims Scenario:

A guest was celebrating her 40th wedding anniversary with her husband at a Las Vegas hotel when she inhaled Legionella bacteria while using the hotel's jacuzzi. She was hospitalized shortly after and died only a week later. During discovery, it was determined the hotel was not only directly responsible for the woman's death, but it was also aware of Legionella being present in its water system months before the victim's stay. **The victim's family was awarded a multi-milliondollar settlement.**

Distinguished benefits you can count on.







The information presented in this publication is intended to provide guidance and is not intended as a legal interpretation of any federal, state or local laws, rules or regulations applicable to your business. The loss prevention information provided is intended only to assist policyholders in the management of potential loss producing conditions involving their premises and/or operations based on generally accepted safe practices. In providing such information, Great American does not warrant that all potential hazards or conditions have been evaluated or can be controlled. It is not intended as an offer to write insurance for such conditions or exposures. The liability of Great American Insurance Company and its affiliated insurers is limited to the terms, limits and conditions of the insurance policies underwritten by any of them. Policies are underwritten by Great American Insurance Company and Great American Alliance Insurance Company, authorized insurers in all 50 states and the DC. © 2021 Great American Insurance Company, 301 E. Fourth St., Cincinnati, OH 45202. All rights reserved. 0138-GRS (06/21)

Find out more information on www.distinguished.com

CA License # 0D06551